

Water Quality Sampling Results

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
0100	TURBIDITY	06-20-2023	0.62		0.1		5	.1	NTU
1002	ALUMINUM	06-20-2023		<	50		1000	50	UG/L
1005	ARSENIC	06-20-2023		<	2		10	2	UG/L
1010	BARIUM	06-20-2023		<	100		1000	100	UG/L
1015	CADMIUM	06-20-2023		<	1		5	1	UG/L
1017	CHLORIDE	06-20-2023	21		1		500		MG/L
1020	CHROMIUM	06-20-2023		<	10		50	10	UG/L
1021	HYDROXIDE AS CALCIUM CARBONATE	06-20-2023		<	5				MG/L
1022	COPPER, FREE	06-20-2023		<	50		1000	50	UG/L
1024	CYANIDE	06-20-2023		<	100		150	100	UG/L
1025	FLUORIDE	06-20-2023	1.2		0.1		2	.1	MG/L
1028	IRON	06-20-2023		<	100		300	100	UG/L
1030	LEAD	06-20-2023		<	5			5	UG/L
1031	MAGNESIUM	06-20-2023	20		1				MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1032	MANGANESE	06-20-2023		<	20		50	20	UG/L
1035	MERCURY	06-20-2023		<	1		2	1	UG/L
1036	NICKEL	06-20-2023		<	10		100	10	UG/L
1038	NITRATE-NITRITE	06-20-2023	0.86		0.4		10	.4	MG/L
1039	PERCHLORATE	06-20-2023		<	2		6	2	UG/L
1040	NITRATE	06-20-2023	0.86		0.4		10	.4	MG/L
1041	NITRITE	06-20-2023		<	0.4		1	.4	MG/L
1042	POTASSIUM	06-20-2023	4.4		1				MG/L
1045	SELENIUM	06-20-2023		<	5		50	5	UG/L
1050	SILVER	06-20-2023		<	10		100	10	UG/L
1052	SODIUM	06-20-2023	83		1				MG/L
1055	SULFATE	06-20-2023	300		0.5		500	.5	MG/L
1064	CONDUCTIVITY @ 25 C UMHOS/CM	06-20-2023	850		2		1600		UMHOCM
1074	ANTIMONY, TOTAL	06-20-2023		<	6		6	6	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1075	BERYLLIUM, TOTAL	06-20-2023		<	1		4	1	UG/L
1079	BORON, TOTAL	06-20-2023	780					100	UG/L
1085	THALLIUM, TOTAL	06-20-2023		<	1		2	1	UG/L
1088	VANADIUM, TOTAL	06-20-2023	8.0						UG/L
1095	ZINC	06-20-2023		<	50		5000	50	UG/L
1905	COLOR	06-20-2023		<	3		15		UNITS
1915	HARDNESS, TOTAL (AS CaCO3)	06-20-2023	230						MG/L
1919	CALCIUM	06-20-2023	60						MG/L
1920	ODOR	06-20-2023	1				3	1	TON
1925	PH	06-20-2023	7.8						pH
1927	ALKALINITY, TOTAL	06-20-2023	82						MG/L
1928	ALKALINITY, BICARBONATE	06-20-2023	100						MG/L
1929	ALKALINITY, CARBONATE	06-20-2023		<	5				MG/L
1930	TDS	06-20-2023	550				1000		MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2218	TRICHLOROFLUOROMETHANE	06-20-2023		<	5		150	5	UG/L
2224	TRANS-1,3-DICHLOROPROPENE	06-20-2023		<	0.5		.5	.5	UG/L
2228	CIS-1,3-DICHLOROPROPENE	06-20-2023		<	0.5		.5	.5	UG/L
2251	METHYL TERT-BUTYL ETHER	06-20-2023		<	3		13	3	UG/L
2378	1,2,4-TRICHLOROBENZENE	06-20-2023		<	0.5		5	.5	UG/L
2380	CIS-1,2-DICHLOROETHYLENE	06-20-2023		<	0.5		6	.5	UG/L
2413	1,3-DICHLOROPROPENE	06-20-2023		<	0.5		.5	.5	UG/L
2414	1,2,3-TRICHLOROPROPANE	06-20-2023		<	0.005		0.005		UG/L
2904	TRICHLOROTRIFLUOROETHANE	06-20-2023		<	10		1200	10	UG/L
2905	FOAMING AGENTS (SURFACTANTS)	06-20-2023		<	0.1		.5		MG/L
2941	CHLOROFORM	06-20-2023		<	1			1	UG/L
2942	BROMOFORM	06-20-2023		<	1			1	UG/L
2943	BROMODICHLOROMETHANE	06-20-2023		<	1			1	UG/L
2944	DIBROMOCHLOROMETHANE	06-20-2023		<	1			1	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2950	TTHM	06-20-2023		<	1		80		UG/L
2955	XYLENES, TOTAL	06-20-2023		<	0.5		1750	0.5	UG/L
2963	XYLENE, META AND PARA	06-20-2023		<	1			.5	UG/L
2964	DICHLOROMETHANE	06-20-2023		<	0.5		5	.5	UG/L
2968	O-DICHLOROBENZENE	06-20-2023		<	0.5		600	.5	UG/L
2969	P-DICHLOROBENZENE	06-20-2023		<	0.5		5	.5	UG/L
2976	VINYL CHLORIDE	06-20-2023		<	0.5		.5	.5	UG/L
2977	1,1-DICHLOROETHYLENE	06-20-2023		<	0.5		6	.5	UG/L
2978	1,1-DICHLOROETHANE	06-20-2023		<	0.5		5	.5	UG/L
2979	TRANS-1,2-DICHLOROETHYLENE	06-20-2023		<	0.5		10	.5	UG/L
2980	1,2-DICHLOROETHANE	06-20-2023		<	0.5		.5	.5	UG/L
2981	1,1,1-TRICHLOROETHANE	06-20-2023		<	0.5		200	.5	UG/L
2982	CARBON TETRACHLORIDE	06-20-2023		<	0.5		.5	.5	UG/L
2983	1,2-DICHLOROPROPANE	06-20-2023		<	0.5		5	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2984	TRICHLOROETHYLENE	06-20-2023		<	0.5		5	.5	UG/L
2985	1,1,2-TRICHLOROETHANE	06-20-2023		<	0.5		5	.5	UG/L
2987	TETRACHLOROETHYLENE	06-20-2023		<	0.5		5	.5	UG/L
2988	1,1,2,2-TETRACHLOROETHANE	06-20-2023		<	0.5		1	.5	UG/L
2989	CHLOROBENZENE	06-20-2023		<	0.5		70	.5	UG/L
2990	BENZENE	06-20-2023		<	0.5		1	.5	UG/L
2991	TOLUENE	06-20-2023		<	0.5		150	.5	UG/L
2992	ETHYLBENZENE	06-20-2023		<	0.5		300	.5	UG/L
2996	STYRENE	06-20-2023		<	0.5		100	.5	UG/L
2997	O-XYLENE	06-20-2023		<	0.5			.5	UG/L
1040	NITRATE	05-16-2022	1.1		0.4		10	.4	MG/L
1920	ODOR	05-16-2022	2		1		3	1	TON
2931	1,2-DIBROMO-3-CHLOROPROPANE	04-13-2022		<	0.01		.2	.01	UG/L
2946	ETHYLENE DIBROMIDE	04-13-2022		<	0.02		.05	.02	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
4109	GROSS ALPHA PARTICLE ACTIVITY	05-17-2021		<	0.6	0.580	15	3	PCI/L
0100	TURBIDITY	05-14-2021	0.1900000		0.1		5	.1	NTU
1017	CHLORIDE	05-14-2021	27.0000000				500		MG/L
1021	HYDROXIDE AS CALCIUM CARBONATE	05-14-2021		<					MG/L
1022	COPPER, FREE	05-14-2021		<	50		1000	50	UG/L
1025	FLUORIDE	05-14-2021	1.6000000		0.1		2	.1	MG/L
1028	IRON	05-14-2021		<	100		300	100	UG/L
1031	MAGNESIUM	05-14-2021	33.0000000						MG/L
1032	MANGANESE	05-14-2021		<	20		50	20	UG/L
1040	NITRATE	05-14-2021	0.8800000		0.4		10	.4	MG/L
1041	NITRITE	05-14-2021		<	0.4		1	.4	MG/L
1042	POTASSIUM	05-14-2021	6.2000000						MG/L
1052	SODIUM	05-14-2021	120.0000000						MG/L
1055	SULFATE	05-14-2021	420.0000000		0.5		500	.5	MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1064	CONDUCTIVITY @ 25 C UMHOS/CM	05-14-2021	1000.0000000				1600		UMHOS/CM
1079	BORON, TOTAL	05-14-2021	1300.0000000		100			100	UG/L
1095	ZINC	05-14-2021		<	50		5000	50	UG/L
1905	COLOR	05-14-2021		<			15		UNITS
1915	HARDNESS, TOTAL (AS CaCO3)	05-14-2021	280.0000000						MG/L
1919	CALCIUM	05-14-2021	60.0000000						MG/L
1925	PH	05-14-2021	7.8000000						pH
1927	ALKALINITY, TOTAL	05-14-2021	68.0000000						MG/L
1928	ALKALINITY, BICARBONATE	05-14-2021	82.0000000						MG/L
1929	ALKALINITY, CARBONATE	05-14-2021		<					MG/L
1930	TDS	05-14-2021	700.0000000				1000		MG/L
1994	AGGRESSIVE INDEX	05-14-2021	11.8000000						AGGR
1997	LANGELIER INDEX (PH(S))	05-14-2021	0.5500000						LANG
2905	FOAMING AGENTS (SURFACTANTS)	05-14-2021		<			.5		MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
C164	LANGELIER INDEX AT SOURCE TEMP.	05-14-2021	-0.0600000						LANG
4030	RADIUM-228	08-19-2020	0.77		0.17	0.200		1	PCI/L
1040	NITRATE	05-11-2020	0.8700000		0.4		10	.4	MG/L
2005	ENDRIN	05-11-2020		<	0.1		2	.1	UG/L
2010	BHC-GAMMA	05-11-2020		<	0.2		.2	.2	UG/L
2015	METHOXYCHLOR	05-11-2020		<	10		30	10	UG/L
2020	TOXAPHENE	05-11-2020		<	1		3	1	UG/L
2031	DALAPON	05-11-2020		<	10		200	10	UG/L
2032	DIQUAT	05-11-2020		<	4		20	4	UG/L
2033	ENDOTHALL	05-11-2020		<	45		100	45	UG/L
2034	GLYPHOSATE	05-11-2020		<	25		700	25	UG/L
2035	DI(2-ETHYLHEXYL) ADIPATE	05-11-2020		<	5		400	5	UG/L
2036	OXAMYL	05-11-2020		<	20		50	20	UG/L
2037	SIMAZINE	05-11-2020		<	1		4	1	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2039	DI(2-ETHYLHEXYL) PHTHALATE	05-11-2020		<	3		4	3	UG/L
2040	PICLORAM	05-11-2020		<	1		500	1	UG/L
2041	DINOSEB	05-11-2020		<	2		7	2	UG/L
2042	HEXACHLOROCYCLOPENTADIENE	05-11-2020		<	1		50	1	UG/L
2046	CARBOFURAN	05-11-2020		<	5		18	5	UG/L
2050	ATRAZINE	05-11-2020		<	0.5		1	.5	UG/L
2051	LASSO	05-11-2020		<	1		2	1	UG/L
2063	2,3,7,8-TCDD	05-11-2020		<	0.005		0.03	0.005	NG/L
2065	HEPTACHLOR	05-11-2020		<			.01	.01	UG/L
2067	HEPTACHLOR EPOXIDE	05-11-2020		<			.01	.01	UG/L
2105	2,4-D	05-11-2020		<	10		70	10	UG/L
2110	2,4,5-TP	05-11-2020		<	1		50	1	UG/L
2218	TRICHLOROFUOROMETHANE	05-11-2020		<	5		150	5	UG/L
2224	TRANS-1,3-DICHLOROPROPENE	05-11-2020		<	0.5		.5	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2228	CIS-1,3-DICHLOROPROPENE	05-11-2020		<	0.5		.5	.5	UG/L
2251	METHYL TERT-BUTYL ETHER	05-11-2020		<	3		13	3	UG/L
2274	HEXACHLOROBENZENE	05-11-2020		<	0.5		1	.5	UG/L
2306	BENZO(A)PYRENE	05-11-2020		<	0.1		.2	.1	UG/L
2326	PENTACHLOROPHENOL	05-11-2020		<	0.2		1	.2	UG/L
2378	1,2,4-TRICHLOROBENZENE	05-11-2020		<	0.5		5	.5	UG/L
2380	CIS-1,2-DICHLOROETHYLENE	05-11-2020		<	0.5		6	.5	UG/L
2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	05-11-2020		<	0.5		.5	.5	UG/L
2413	1,3-DICHLOROPROPENE	05-11-2020		<	0.5		.5	.5	UG/L
2625	BENTAZON	05-11-2020		<	2		18	2	UG/L
2626	MOLINATE	05-11-2020		<	2		20	2	UG/L
2727	THIOBENCARB (BOLERO)	05-11-2020		<	1		70	1	UG/L
2904	TRICHLOROTRIFLUOROETHANE	05-11-2020		<	10		1200	10	UG/L
2941	CHLOROFORM	05-11-2020		<	1			1	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2942	BROMOFORM	05-11-2020		<	1			1	UG/L
2943	BROMODICHLOROMETHANE	05-11-2020		<	1			1	UG/L
2944	DIBROMOCHLOROMETHANE	05-11-2020		<	1			1	UG/L
2950	TTHM	05-11-2020		<			80		UG/L
2955	XYLENES, TOTAL	05-11-2020		<	0.5		1750	0.5	UG/L
2959	CHLORDANE	05-11-2020		<	0.1		.1	.1	UG/L
2963	XYLENE, META AND PARA	05-11-2020		<	0.5			.5	UG/L
2964	DICHLOROMETHANE	05-11-2020		<	0.5		5	.5	UG/L
2968	O-DICHLOROBENZENE	05-11-2020		<	0.5		600	.5	UG/L
2969	P-DICHLOROBENZENE	05-11-2020		<	0.5		5	.5	UG/L
2976	VINYL CHLORIDE	05-11-2020		<	0.5		.5	.5	UG/L
2977	1,1-DICHLOROETHYLENE	05-11-2020		<	0.5		6	.5	UG/L
2978	1,1-DICHLOROETHANE	05-11-2020		<	0.5		5	.5	UG/L
2979	TRANS-1,2-DICHLOROETHYLENE	05-11-2020		<	0.5		10	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2980	1,2-DICHLOROETHANE	05-11-2020		<	0.5		.5	.5	UG/L
2981	1,1,1-TRICHLOROETHANE	05-11-2020		<	0.5		200	.5	UG/L
2982	CARBON TETRACHLORIDE	05-11-2020		<	0.5		.5	.5	UG/L
2983	1,2-DICHLOROPROPANE	05-11-2020		<	0.5		5	.5	UG/L
2984	TRICHLOROETHYLENE	05-11-2020		<	0.5		5	.5	UG/L
2985	1,1,2-TRICHLOROETHANE	05-11-2020		<	0.5		5	.5	UG/L
2987	TETRACHLOROETHYLENE	05-11-2020		<	0.5		5	.5	UG/L
2988	1,1,2,2-TETRACHLOROETHANE	05-11-2020		<	0.5		1	.5	UG/L
2989	CHLOROBENZENE	05-11-2020		<	0.5		70	.5	UG/L
2990	BENZENE	05-11-2020		<	0.5		1	.5	UG/L
2991	TOLUENE	05-11-2020		<	0.5		150	.5	UG/L
2992	ETHYLBENZENE	05-11-2020		<	0.5		300	.5	UG/L
2996	STYRENE	05-11-2020		<	0.5		100	.5	UG/L
2997	O-XYLENE	05-11-2020		<	0.5			.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
4030	RADIUM-228	05-11-2020	2.0200000		0.2	0.340		1	PCI/L
4030	RADIUM-228	04-21-2020	1.5000000		0.3	0.350		1	PCI/L
4030	RADIUM-228	02-12-2020	1.5500000		0.3	0.280		1	PCI/L
2414	1,2,3-TRICHLOROPROPANE	07-16-2019		<			0.005		UG/L
4030	RADIUM-228	06-24-2019	0.5700000		0.1	0.110		1	PCI/L
0100	TURBIDITY	05-21-2019	0.2000000		0.1		5	.1	NTU
1017	CHLORIDE	05-21-2019	28.0000000				500		MG/L
1021	HYDROXIDE AS CALCIUM CARBONATE	05-21-2019		<					MG/L
1022	COPPER, FREE	05-21-2019		<	50		1000	50	UG/L
1025	FLUORIDE	05-21-2019	1.5000000		0.1		2	.1	MG/L
1028	IRON	05-21-2019		<	100		300	100	UG/L
1031	MAGNESIUM	05-21-2019	25.0000000						MG/L
1032	MANGANESE	05-21-2019		<	20		50	20	UG/L
1040	NITRATE	05-21-2019	0.9000000		0.4		10	.4	MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1042	POTASSIUM	05-21-2019	4.7000000						MG/L
1052	SODIUM	05-21-2019	110.0000000						MG/L
1055	SULFATE	05-21-2019	460.0000000		0.5		500	.5	MG/L
1064	CONDUCTIVITY @ 25 C UMHOS/CM	05-21-2019	1100.0000000				1600		UMHOS/CM
1079	BORON, TOTAL	05-21-2019	1300.0000000		100			100	UG/L
1095	ZINC	05-21-2019		<	50		5000	50	UG/L
1905	COLOR	05-21-2019		<			15		UNITS
1915	HARDNESS, TOTAL (AS CaCO3)	05-21-2019	290.0000000						MG/L
1919	CALCIUM	05-21-2019	75.0000000						MG/L
1920	ODOR	05-21-2019	1.0000000		1		3	1	TON
1925	PH	05-21-2019	7.7000000						pH
1927	ALKALINITY, TOTAL	05-21-2019	63.0000000						MG/L
1928	ALKALINITY, BICARBONATE	05-21-2019	77.0000000						MG/L
1929	ALKALINITY, CARBONATE	05-21-2019		<					MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1930	TDS	05-21-2019	730.0000000				1000		MG/L
1994	AGGRESSIVE INDEX	05-21-2019	11.7200000						AGGR
1997	LANGELIER INDEX (PH(S))	05-21-2019	0.4700000						LANG
2905	FOAMING AGENTS (SURFACTANTS)	05-21-2019		<			.5		MG/L
C164	LANGELIER INDEX AT SOURCE TEMP.	05-21-2019	-0.1300000						LANG
1040	NITRATE	05-09-2019		<	0.4		10	.4	MG/L
2414	1,2,3-TRICHLOROPROPANE	04-17-2019		<			0.005		UG/L
2931	1,2-DIBROMO-3-CHLOROPROPANE	04-17-2019		<			.2	.01	UG/L
2946	ETHYLENE DIBROMIDE	04-17-2019		<			.05	.02	UG/L
2414	1,2,3-TRICHLOROPROPANE	02-12-2019		<			0.005		UG/L
2414	1,2,3-TRICHLOROPROPANE	12-10-2018		<			0.005		UG/L
2414	1,2,3-TRICHLOROPROPANE	09-19-2018		<			0.005		UG/L
0100	TURBIDITY	05-14-2018	0.1000000		0.1		5	.1	NTU
1002	ALUMINUM	05-14-2018		<	50		1000	50	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1005	ARSENIC	05-14-2018		<	2		10	2	UG/L
1010	BARIUM	05-14-2018		<	100		1000	100	UG/L
1015	CADMIUM	05-14-2018		<	1		5	1	UG/L
1020	CHROMIUM	05-14-2018		<	10		50	10	UG/L
1024	CYANIDE	05-14-2018		<	100		150	100	UG/L
1025	FLUORIDE	05-14-2018	1.5000000		0.1		2	.1	MG/L
1030	LEAD	05-14-2018		<	5			5	UG/L
1035	MERCURY	05-14-2018		<	1		2	1	UG/L
1036	NICKEL	05-14-2018		<	10		100	10	UG/L
1038	NITRATE-NITRITE	05-14-2018	0.6200000		0.4		10	.4	MG/L
1039	PERCHLORATE	05-14-2018		<	4		6	4	UG/L
1040	NITRATE	05-14-2018	0.6200000		0.4		10	.4	MG/L
1041	NITRITE	05-14-2018		<	0.4		1	.4	MG/L
1045	SELENIUM	05-14-2018		<	5		50	5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1050	SILVER	05-14-2018		<	10		100	10	UG/L
1074	ANTIMONY, TOTAL	05-14-2018		<	6		6	6	UG/L
1075	BERYLLIUM, TOTAL	05-14-2018		<	1		4	1	UG/L
1080	CHROMIUM, HEX	05-14-2018	1.5000000		1			1	UG/L
1085	THALLIUM, TOTAL	05-14-2018		<	1		2	1	UG/L
1088	VANADIUM, TOTAL	05-14-2018	10.0000000		3				UG/L
1905	COLOR	05-14-2018		<			15		UNITS
1920	ODOR	05-14-2018	1.0000000		1		3	1	TON
4109	GROSS ALPHA PARTICLE ACTIVITY	05-14-2018		<	2	4.700	15	3	PCI/L
4109	GROSS ALPHA PARTICLE ACTIVITY	04-11-2018		<	2.2	3.700	15	3	PCI/L
2414	1,2,3-TRICHLOROPROPANE	03-08-2018		<			0.005		UG/L
1055	SULFATE	12-07-2017	450.0000000		0.5		500	.5	MG/L
1055	SULFATE	09-18-2017	460.0000000		0.5		500	.5	MG/L
1055	SULFATE	06-04-2017	510.0000000		0.5		500	.5	MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1040	NITRATE	05-10-2017	0.4100000		0.4		10	.4	MG/L
1055	SULFATE	03-06-2017	540.0000000		0.5		500	.5	MG/L
1055	SULFATE	12-05-2016	540.0000000		0.5		500	.5	MG/L
1055	SULFATE	09-29-2016	560.0000000		0.5		500	.5	MG/L
2414	1,2,3-TRICHLOROPROPANE	06-07-2016		<				0.005	UG/L
1055	SULFATE	06-01-2016	550.0000000		0.5		500	.5	MG/L
1040	NITRATE	05-02-2016	0.5100000		0.4		10	.4	MG/L
1041	NITRITE	05-02-2016		<	0.4		1	.4	MG/L
2218	TRICHLOROFLUOROMETHANE	05-02-2016		<	5		150	5	UG/L
2224	TRANS-1,3-DICHLOROPROPENE	05-02-2016		<	0.5		.5	.5	UG/L
2228	CIS-1,3-DICHLOROPROPENE	05-02-2016		<	0.5		.5	.5	UG/L
2251	METHYL TERT-BUTYL ETHER	05-02-2016		<	3		13	3	UG/L
2378	1,2,4-TRICHLOROBENZENE	05-02-2016		<	0.5		5	.5	UG/L
2380	CIS-1,2-DICHLOROETHYLENE	05-02-2016		<	0.5		6	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2413	1,3-DICHLOROPROPENE	05-02-2016		<	0.5		.5	.5	UG/L
2904	TRICHLOROTRIFLUOROETHANE	05-02-2016		<	10		1200	10	UG/L
2941	CHLOROFORM	05-02-2016		<	1			1	UG/L
2942	BROMOFORM	05-02-2016		<	1			1	UG/L
2943	BROMODICHLOROMETHANE	05-02-2016		<	1			1	UG/L
2944	DIBROMOCHLOROMETHANE	05-02-2016		<	1			1	UG/L
2950	TTHM	05-02-2016		<			80		UG/L
2955	XYLENES, TOTAL	05-02-2016		<	0.5		1750	0.5	UG/L
2963	XYLENE, META AND PARA	05-02-2016		<	0.5			.5	UG/L
2964	DICHLOROMETHANE	05-02-2016		<	0.5		5	.5	UG/L
2968	O-DICHLOROBENZENE	05-02-2016		<	0.5		600	.5	UG/L
2969	P-DICHLOROBENZENE	05-02-2016		<	0.5		5	.5	UG/L
2976	VINYL CHLORIDE	05-02-2016		<	0.5		.5	.5	UG/L
2977	1,1-DICHLOROETHYLENE	05-02-2016		<	0.5		6	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2978	1,1-DICHLOROETHANE	05-02-2016		<	0.5		5	.5	UG/L
2979	TRANS-1,2-DICHLOROETHYLENE	05-02-2016		<	0.5		10	.5	UG/L
2980	1,2-DICHLOROETHANE	05-02-2016		<	0.5		.5	.5	UG/L
2981	1,1,1-TRICHLOROETHANE	05-02-2016		<	0.5		200	.5	UG/L
2982	CARBON TETRACHLORIDE	05-02-2016		<	0.5		.5	.5	UG/L
2983	1,2-DICHLOROPROPANE	05-02-2016		<	0.5		5	.5	UG/L
2984	TRICHLOROETHYLENE	05-02-2016		<	0.5		5	.5	UG/L
2985	1,1,2-TRICHLOROETHANE	05-02-2016		<	0.5		5	.5	UG/L
2987	TETRACHLOROETHYLENE	05-02-2016		<	0.5		5	.5	UG/L
2988	1,1,2,2-TETRACHLOROETHANE	05-02-2016		<	0.5		1	.5	UG/L
2989	CHLOROBENZENE	05-02-2016		<	0.5		70	.5	UG/L
2990	BENZENE	05-02-2016		<	0.5		1	.5	UG/L
2991	TOLUENE	05-02-2016		<	0.5		150	.5	UG/L
2992	ETHYLBENZENE	05-02-2016		<	0.5		300	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2996	STYRENE	05-02-2016		<	0.5		100	.5	UG/L
2997	O-XYLENE	05-02-2016		<	0.5			.5	UG/L
1055	SULFATE	03-10-2016	540.0000000		0.5		500	.5	MG/L
1055	SULFATE	12-01-2015	490.0000000		0.5		500	.5	MG/L
1055	SULFATE	09-01-2015	510.0000000		0.5		500	.5	MG/L
1055	SULFATE	06-12-2015	510.0000000		0.5		500	.5	MG/L
0100	TURBIDITY	05-04-2015	0.9000000		0.1		5	.1	NTU
1002	ALUMINUM	05-04-2015		<	50		1000	50	UG/L
1005	ARSENIC	05-04-2015		<	2		10	2	UG/L
1010	BARIUM	05-04-2015		<	100		1000	100	UG/L
1015	CADMIUM	05-04-2015		<	1		5	1	UG/L
1017	CHLORIDE	05-04-2015	30.0000000				500		MG/L
1020	CHROMIUM	05-04-2015		<	10		50	10	UG/L
1021	HYDROXIDE AS CALCIUM CARBONATE	05-04-2015		<					MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1022	COPPER, FREE	05-04-2015		<	50		1000	50	UG/L
1024	CYANIDE	05-04-2015		<	100		150	100	UG/L
1025	FLUORIDE	05-04-2015	1.1000000		0.1		2	.1	MG/L
1028	IRON	05-04-2015	130.0000000		100		300	100	UG/L
1030	LEAD	05-04-2015		<	5			5	UG/L
1031	MAGNESIUM	05-04-2015	38.0000000						MG/L
1032	MANGANESE	05-04-2015		<	20		50	20	UG/L
1035	MERCURY	05-04-2015		<	1		2	1	UG/L
1036	NICKEL	05-04-2015		<	10		100	10	UG/L
1038	NITRATE-NITRITE	05-04-2015	770.0000000		400		10000	400	UG/L
1039	PERCHLORATE	05-04-2015		<	4		6	4	UG/L
1041	NITRITE	05-04-2015		<	400		1000	400	UG/L
1042	POTASSIUM	05-04-2015	7.4000000						MG/L
1045	SELENIUM	05-04-2015		<	5		50	5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1050	SILVER	05-04-2015		<	10		100	10	UG/L
1052	SODIUM	05-04-2015	110.0000000						MG/L
1055	SULFATE	05-04-2015	510.0000000		0.5		500	.5	MG/L
1064	CONDUCTIVITY @ 25 C UMHOS/CM	05-04-2015	1200.0000000				1600		UMHOS/CM
1074	ANTIMONY, TOTAL	05-04-2015		<	6		6	6	UG/L
1075	BERYLLIUM, TOTAL	05-04-2015		<	1		4	1	UG/L
1079	BORON, TOTAL	05-04-2015	1200.0000000		100			100	UG/L
1085	THALLIUM, TOTAL	05-04-2015		<	1		2	1	UG/L
1088	VANADIUM, TOTAL	05-04-2015	7.0000000		3				UG/L
1095	ZINC	05-04-2015		<	50		5000	50	UG/L
1905	COLOR	05-04-2015		<			15		UNITS
1915	HARDNESS, TOTAL (AS CaCO3)	05-04-2015	370.0000000						MG/L
1919	CALCIUM	05-04-2015	84.0000000						MG/L
1920	ODOR	05-04-2015	1.0000000		1		3	1	TON

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1925	PH	05-04-2015	7.7000000						pH
1927	ALKALINITY, TOTAL	05-04-2015	56.0000000						MG/L
1928	ALKALINITY, BICARBONATE	05-04-2015	69.0000000						MG/L
1929	ALKALINITY, CARBONATE	05-04-2015		<					MG/L
1930	TDS	05-04-2015	820.0000000				1000		MG/L
1994	AGGRESSIVE INDEX	05-04-2015	11.8100000						AGGR
1996	TEMPERATURE (CENTIGRADE)	05-04-2015	20.0000000						C
1997	LANGELIER INDEX (PH(S))	05-04-2015	0.5600000						LANG
2905	FOAMING AGENTS (SURFACTANTS)	05-04-2015		<			.5		MG/L
2931	1,2-DIBROMO-3-CHLOROPROPANE	05-04-2015		<			.2	.01	UG/L
2946	ETHYLENE DIBROMIDE	05-04-2015		<			.05	.02	UG/L
C164	LANGELIER INDEX AT SOURCE TEMP.	05-04-2015	-0.0500000						LANG
C255	NITRATE (AS NO3)	05-04-2015	3.4000000		2		45	2	MG/L
4109	GROSS ALPHA PARTICLE ACTIVITY	04-23-2015	8.5000000		2.4	3.000	15	3	PCI/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
4109	GROSS ALPHA PARTICLE ACTIVITY	04-08-2015	15.0000000		2.3	3.600	15	3	PCI/L
1080	CHROMIUM, HEX	07-01-2014		<	1		10	1	UG/L
C255	NITRATE (AS NO3)	06-02-2014	6.3000000		2		45	2	MG/L
C255	NITRATE (AS NO3)	06-03-2013	1.9000000		2		45	2	MG/L
0100	TURBIDITY	05-07-2012	0.6000000		0.1		5	.1	NTU
1002	ALUMINUM	05-07-2012		<	50		1000	50	UG/L
1005	ARSENIC	05-07-2012	2.2000000		2		10	2	UG/L
1010	BARIUM	05-07-2012		<	100		1000	100	UG/L
1015	CADMIUM	05-07-2012		<	1		5	1	UG/L
1017	CHLORIDE	05-07-2012	9.8000000				500		MG/L
1020	CHROMIUM	05-07-2012	2.1000000		10		50	10	UG/L
1021	HYDROXIDE AS CALCIUM CARBONATE	05-07-2012		<	3				MG/L
1022	COPPER, FREE	05-07-2012	60.0000000		50		1000	50	UG/L
1024	CYANIDE	05-07-2012		<	100		150	100	UG/L
1025	FLUORIDE	05-07-2012	1.1000000		0.1		2	.1	MG/L
1028	IRON	05-07-2012	110.0000000		100		300	100	UG/L
1030	LEAD	05-07-2012		<	5			5	UG/L
1031	MAGNESIUM	05-07-2012	11.0000000						MG/L
1032	MANGANESE	05-07-2012		<	20		50	20	UG/L
1035	MERCURY	05-07-2012		<	1		2	1	UG/L
1036	NICKEL	05-07-2012		<	10		100	10	UG/L
1039	PERCHLORATE	05-07-2012		<	4		6	4	UG/L
1041	NITRITE	05-07-2012		<	100		1000	400	UG/L
1042	POTASSIUM	05-07-2012	3.3000000						MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1045	SELENIUM	05-07-2012		<	5		50	5	UG/L
1050	SILVER	05-07-2012		<	10		100	10	UG/L
1052	SODIUM	05-07-2012	40.0000000						MG/L
1055	SULFATE	05-07-2012	76.0000000		0.5		500	.5	MG/L
1064	CONDUCTIVITY @ 25 C UMHOS/CM	05-07-2012	400.0000000				1600		UMHOS/CM
1074	ANTIMONY, TOTAL	05-07-2012		<	6		6	6	UG/L
1075	BERYLLIUM, TOTAL	05-07-2012		<	1		4	1	UG/L
1085	THALLIUM, TOTAL	05-07-2012		<	1		2	1	UG/L
1095	ZINC	05-07-2012	260.0000000		50		5000	50	UG/L
1905	COLOR	05-07-2012		<	3		15		UNITS
1915	HARDNESS, TOTAL (AS CaCO3)	05-07-2012	110.0000000						MG/L
1919	CALCIUM	05-07-2012	27.0000000						MG/L
1920	ODOR	05-07-2012		<	1		3	1	TON
1925	PH	05-07-2012	7.9000000						pH
1927	ALKALINITY, TOTAL	05-07-2012	89.0000000						MG/L
1928	ALKALINITY, BICARBONATE	05-07-2012	110.0000000						MG/L
1929	ALKALINITY, CARBONATE	05-07-2012		<	3				MG/L
1930	TDS	05-07-2012	240.0000000				1000		MG/L
2063	2,3,7,8-TCDD	05-07-2012		<			0.03	0.005	NG/L
2905	FOAMING AGENTS (SURFACTANTS)	05-07-2012		<	0.1		.5		MG/L
2931	1,2-DIBROMO-3-CHLOROPROPANE	05-07-2012		<			.2	.01	UG/L
2946	ETHYLENE DIBROMIDE	05-07-2012		<			.05	.02	UG/L
C255	NITRATE (AS NO3)	05-07-2012	2.2000000		2		45	2	MG/L
4109	GROSS ALPHA PARTICLE ACTIVITY	04-02-2012	0.3200000		3	0.580	15	3	PCI/L
4030	RADIUM-228	12-19-2011		<	0.2	0.553		1	PCI/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
4109	GROSS ALPHA PARTICLE ACTIVITY	12-19-2011	0.6300000		3	0.650	15	3	PCI/L
C255	NITRATE (AS NO3)	07-05-2011	16.0000000		2		45	2	MG/L